

664 State Street / PO Box 496 Beaver, PA 15009 Phone 724.775.7926 Fax 724.775.5283

# **( Example 2** Declaration of Conformity

This Declaration of Conformity is established to support claims that the products listed are in compliance with the Relevant Standards and Directives; and that "Due Diligence" has been exhibited in efforts to prove, through testing and evaluation, that these products meet those applicable requirements.

### **Products Involved:**

Factory Sealed Contact Blocks for use in Hazardous Locations

Series **CBFS** 1NO-1NC Contact Block with mounting bracket (rated A600 AC & P300 DC) Series **CBFSR** 1NO-1NC Contact Block with mounting bracket (rated A600 AC & P300 DC)

## **Classifications:**

Class I Div. 2 Group A, B, C, D Class I Div. 1 (R/C UL only)

### **Relevant Standards & Directives:**

Low Voltage Directive 2014/35/EC and RoHS Directive 2011/65/EU

EN 60947-1:2007 Low-Voltage Switchgear and Controlgear, Part 1 General Rules
EN 60947-5-1:2004 Low-Voltage Switchgear and Controlgear, Part 5, Control
Circuit Devices and Switching Elements – Section 1

Electromechanical Control Circuit Devices

UL 508 Industrial Control Equipment

ANSI/ISA 12.12.01-2011 Electrical Equipment for use in Class I, II Div 2; Class II

Hazardous (Classified) Locations

CSA C22.2 No. 14 Industrial Control Equipment

CSA C22.2 No. 213 Non-Incendive Elec. Equipment for use in Class I Div. 2

**Hazardous Locations** 

## **Records:**

**UL Procedures and Test Records** 

File # E157436 Vol. 1 Sec. 5 Listed – US – CL. I Div. 2 File # E157436 Vol. 2 Sec. 1 R/C – US – CL. I Div. 1

CSA Procedures and Test Records

File # LR 47446-14 Class No. 3218-06

Peter A. Damesimo, Director, R&D and Product Marketing

December 5, 2016

Year of CE Marking: 2005