



## Certification Record

CUSTOMER	CLASS	FILE
c3controls Control Concepts Corporation 664 State St, Beaver PA 15009 USA	<a href="#">3218-06</a>  INDUSTRIAL CONTROL EQUIPMENT-Miscellaneous Apparatus - For Hazardous Locations	227135
<b>Refer to Class Description for program details</b>		

Class I, Div 2, Groups A, B, C and D:

Relays, open type with sealed dust cover, hermetically sealed type, HGPRM-B4C05C, HGPRM-B4C05D, HGPRM-B4C05F, HGPRM-B4C05ZB, HGPRM-B4C05ZC AND HGPRM-B4C05ZD, 4-pole, double-throw; for use with MAGNECRAFT mounting socket, P/N's 70-378-1, 70-379-1 and 70-461-1; Temperature Code T4A; electrical rating as follows.

Contact Rating	Electrical Rating	No. Of Operations	Ambient Tested
1A	1A (resistive), 120/240V ac, 50/60 Hz; 1A, 30V dc	100,000	70°C
3A	3A (resistive), 120/240V ac, 50/60 Hz; 3A, 30V dc	100,000	70°C
5A	5A (resistive), 120/240V ac, 50/60Hz; 5A, 30V dc	35,000	70°C

Coil - 6 through 240V

Note: Open type devices are Certified as components for use only in other Certified equipment where the suitability of the combination is to be determined by the CSA International.

/ka