

CERTIFICATE OF COMPLIANCE

Certificate Number 20141111-E68568
Report Reference E68568-20130601
Issue Date 2014-NOVEMBER-11

Issued to: C3CONTROLS
664 STATE ST PO BOX 496 BEAVER PA 15009-0496

**This is to certify that
representative samples of**

AUXILIARY DEVICES

Open Type thermal overload relay, Cat. Nos. 320-B2C40,
320-B2C63, 320-B2C80, 320-B2D12, 320-B2D18,
320-B2D28, 320-B2D40, 320-B2D63, 320-B2D80,
320-B2U10, 320-B2U12, 320-B2U15, 320-B2U17,
320-B2U23, 320-B2U32, 320-B3U40.

GENERAL:

The above devices are of open type, ambient compensated
and adjustable, 3 phase thermal overload relays.

The overload relay shall be used with the 300-S or 310-S
Series contactor or mounting adapters.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: Low-Voltage Switchgear and Controlgear – Part 4-1:
Contactors and motor-starters – Electromechanical
contactors and motor-starters, UL 60947-4-1A and CSA
C22.2 NO 60947-4-1-07

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20141111-E68568
Report Reference E68568-20130601
Issue Date 2014-NOVEMBER-11

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

