

XCFR8.E145984 - Terminal Blocks Certified for Canada - Component

Terminal Blocks Certified for Canada - Component

See General Information for Terminal Blocks Certified for Canada - Component

C3CONTROLS

664 STATE ST
PO BOX 496
BEAVER, PA 15009 USA

E145984


Cat. No.	Wire Range	Wire Type	TQ N-M	V	A	UG	CA
HDTB-4, HDTB-6, and HDTB-12	18-10, SOL/STR	Cu	2.03 - 2.26	600	30	B, C	2 (105),4
WTB2-W2	22-12, SOL/STR	Cu	0.8	600	20(1)	B,C	2 (105),4
WTB2-W4	22-10, SOL/STR	Cu	0.8	600	30(2)	B,C	2 (105),4
WTB2-W6	22-8, SOL/STR	Cu	1.0	600	50	B,C	2 (105),4
WTB2-W10	18-6, STR	Cu	1.6	600	65	B,C	2 (105),4
WTB2-W16	16-4, STR	Cu	1.6	600	85	B,C	2 (105),4
WTB2-W25	14-3, STR	Cu	1.6	600	100(3)	B,C	2 (105),4
WTB2-W35	8-2, STR	Cu	2.9	600	115(4)	B,C	2 (105),4
WTB2-FB52	22-10, SOL/STR	Cu	0.8	600	10	B,C	2 (105),4,#
WTB2-FB52L	22-10, SOL/STR	Cu	0.8	600	10	B,C	2 (105),4,#
WTB2-FB52DB	22-10, SOL/STR	Cu	0.8	600	16	B,C	2 (105),4,#
WTB2-W70	2/0-6, STR	Cu	6.8	600	150	B,C	2 (105), 4
WTB2-W95	4/0-2, STR	Cu	18	600	230	B,C	2 (105), 4
WTB2S-W2	22-14, SOL/STR	Cu	N/A (6)	600	15	B,C	2 (105), 4
WTB2S-W2-12	22-14, SOL/STR	Cu	N/A (6)	600	15	B,C	2 (105), 4
WTB2S-W2-22	22-14, SOL/STR	Cu	N/A (6)	600	15	B,C	2 (105), 4
WTB2S-MW2	22-14, SOL/STR	Cu	N/A (6)	600	15	B,C	2 (105), 4
WTB2S-MW2-22	22-14, SOL/STR	Cu	N/A (6)	600	15	B,C	2 (105), 4
WTB2S-W4	22-12, SOL/STR	Cu	N/A (6)	600	20	B,C	2 (105), 4

WTB2S-W4-12	22-12, SOL/STR	Cu	N/A (6)	600	20	B,C	2 (105), 4
WTB2S-W4-22	22-12, SOL/STR	Cu	N/A (6)	600	20	B,C	2 (105), 4
WTB2S-W6	22-8, SOL/STR	Cu	N/A (6)	600	50	B,C	2 (105), 4
WTB2S-W6-12	22-8, SOL/STR	Cu	N/A (6)	600	50	B,C	2 (105), 4
WTB2S-W6-22	22-8, SOL/STR	Cu	N/A (6)	600	50	B,C	2 (105), 4
WTB2-FB1	22-10 Sol/Str	Cu	0.8	600	16	B,C	2(105),4, #
WTB2-FB1L	22-10 Sol/Str	Cu	0.8	600	16	B,C	2(105),4, #
WTB2-FB130-NF	20-6 Str	Cu	1.6	600	30	B,C	2(105),4, #
WTB2-FB130L110A-NF	20-6 Str	Cu	1.6	600	30	B,C	2(105),4, #
WTB2-PDB80	8-4 Str*, 8-4 Str**	Cu	1.6	600	80	B,C	2(105),4
	14-10 Str**		0.8		30		
Note: * represents - Input and Double							
Note: ** represents - Output (any combination of output can be connected one at a time)							
Note: # Terminal blocks are intended for use with miscellaneous fuses							
Note: (1) - 25 A max. for factory-wiring only							
Note: (2) - 35 A max. for factory-wiring only							
Note: (3) - 115 A max. for factory-wiring only							
Note: (4) - 145 A max. for factory-wiring only							
Note: (6) - Spring Force Connection Type Terminal Block							
Note A - These limited ratings are applicable to a terminal block for use in or with industrial control equipment whereby the load on any single circuit of the terminal block does not exceed 15 A at 51-150 V, 10 A at 151-300 V, or 5 A at 301-600 V, or the maximum ampere rating, whichever is less.							

PCTB Terminal Blocks

Cat. No.	Wire Range	Wire Type	TQ N-M	V	A	UG	CA
WTB2-W6/10G	16-6, STR	Cu	1.6	600	N/A	B,C,D	2 (105),4
WTB2-W2/4G	22-10, SOL/STR	Cu	0.79	600	N/A	B,C	2(105),4
WTB2-W16/35G	8-2, STR	Cu	2.82	600	N/A	B,C	2(105),4
WTB2S-W2G	22-14, SOL/STR	Cu	N/A (6)	600	N/A	B,C	2(105),4
WTB2S-W4G	22-12, SOL/STR	Cu	N/A (6)	600	N/A	B,C	2(105),4

WTB2S-W6G	22-8, SOL/STR	Cu	N/A (6)	600	N/A	B,C	2(105),4
Note: (6) - Spring Force Connection Type Terminal Block							

Marking: Company name and Recognized Component Mark for Canada, , on the product. Catalog designation, maximum voltage, wire range, and ampere rating appear on the device or, in or on the carton.

Last Updated on 2018-12-26

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2020 UL LLC"